



Vista Labs

Analytical • Biological • Environmental
An ISO 9001:2015 &
OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

TEST REPORT

Page 1 of 1

Name & Address Of Customer: M/s. Delhi School H.No-4-350/1/1, Anjanadri Nagar, Dammaiguda, Keesara, Medchal-Malkajigiri Dist.	Lab Ref. No:	VIS/2947/2025
	Reporting Date:	20/08/2025
Sample Description: Bore water	Sample Received On:	20/08/2025
	Your Ref No:	Verbal
Sample Condition At the time of Receipt: Found OK	Analysis Started On:	20/08/2025
Sample drawn By: Customer	Date of Sampling:	20/08/2025
Quantity Received: 1Ltr XI No.	Analysis Completed On:	20/08/2025

TEST RESULTS



Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P ^H Value at 25°C	IS:3025(Part -11)-1983,RA 2017	7.52	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	2100	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	1408	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	1.40	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part -4)-1983,RA 2017	02	< 05
6.	Odour	IS:3025(Part -5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009,RA 2014	688	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	380	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991,RA 2014	156	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	71.5	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	149.9	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	27.3	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	355	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986,RA 2014	127.7	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988,RA 2014	45.9	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	1.80	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	21.5	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.115	< 0.3

Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

IS 10500: 2012 = Drinking water Specification

***** End of Report*****

 Checked By	 Authorized Signatory
---	---

VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com

OFFICE OF THE DISTRICT MEDICAL AND HEALTH OFFICER,
MEDCHAL - MALKAJGIRI DISTRICT.

Rc.No. 883 / SHP / DM&HO / Medchal / 2026 - 27.

Dated: 29 / 01 / 2026.

SANITARY CERTIFICATE

I here by certified that Our Health Supervisor inspected the M/s Delhi Public School Dammaiguda, Located at Anjanadri Nagar, Keesara Mandal, Medchal - Malkajgiri District building and premises and certify that the accommodation provided for each of the several classes is sufficient for maximum number of pupils taught therein, and is properly ventilated and lighted, that the building is maintained in substantial repairs, is neat and clean, that the urinals & latrine arrangements are adequate and satisfactory and the supply of Safe drinking water is wholesome, and in all other necessary respects the Hygienic and sanitation is in good condition, for the Academic Year 2026 - 27.

This certificate should be got renewed by the starting of every academic year by applying to the District Medical & Health Officer, Medchal District.


District Medical & Health Officer,
Dist. Medical & Health Officer
Medchal District,
Medchal Dist., Telangana